



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Saint Justine Nursery, Inc. III
360 New York Ave.

Newark, NJ 07105

Laboratory Director:

Attention: Keyla Rufino

Client Number: SAI04

Report Date: 06/26/2025

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Field Blank

Lab Sample ID: 250610085-01

Site: Collection Date/Time: 06/10/2025 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:10	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 12:54	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 101 Teacher Sink

Lab Sample ID: 250610085-02

Site: Collection Date/Time: 06/10/2025 06:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:13	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 12:57	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 101 Kids Bathroom
Sink

Lab Sample ID: 250610085-03

Site: Collection Date/Time: 06/10/2025 06:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:17	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:05	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 101 Water Fountain

Lab Sample ID: 250610085-04

Site: Collection Date/Time: 06/10/2025 06:23

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:20	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:08	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 102 Teacher Sink

Lab Sample ID: 250610085-05

Site: Collection Date/Time: 06/10/2025 06:24

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:23	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:11	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 102 Kids Bathroom
Sink

Lab Sample ID: 250610085-06

Site: Collection Date/Time: 06/10/2025 06:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:26	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:14	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 102 Water Fountain

Lab Sample ID: 250610085-07

Site: Collection Date/Time: 06/10/2025 06:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:29	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:17	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 103 Teacher Sink

Lab Sample ID: 250610085-08

Site: Collection
Date/Time: 06/10/2025 06:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:33	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:25	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 103 Kids Bathroom
Sink

Lab Sample ID: 250610085-09

Site: Collection
Date/Time: 06/10/2025 06:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:36	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:28	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 103 Water Fountain

Lab Sample ID: 250610085-10

Site: Collection
Date/Time: 06/10/2025 06:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:49	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:31	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 104 Teacher Sink

Lab Sample ID: 250610085-11

Site: Collection
Date/Time: 06/10/2025 06:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:52	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:33	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 104 Kids Bathroom
Sink

Lab Sample ID: 250610085-12

Site: Collection
Date/Time: 06/10/2025 06:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:55	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:36	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 104 Water Fountain

Lab Sample ID: 250610085-13

Site: Collection
Date/Time: 06/10/2025 06:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 14:58	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:39	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 105 Teacher Sink

Lab Sample ID: 250610085-14

Site: Collection
Date/Time: 06/10/2025 06:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:01	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:42	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 105 Kids Bathroom
Sink

Lab Sample ID: 250610085-15

Site: Collection
Date/Time: 06/10/2025 06:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:05	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:45	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 105 Water Fountain

Lab Sample ID: 250610085-16

Site: Collection Date/Time: 06/10/2025 06:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:08	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:48	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 201 Teacher Sink

Lab Sample ID: 250610085-17

Site: Collection Date/Time: 06/10/2025 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:11	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 13:50	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 201 Kids Bathroom Sink

Lab Sample ID: 250610085-18

Site: Collection Date/Time: 06/10/2025 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:14	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:02	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 201 Water Fountain

Lab Sample ID: 250610085-19

Site: Collection Date/Time: 06/10/2025 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:17	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:05	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 202 Teacher Sink

Lab Sample ID: 250610085-20

Site: Collection
Date/Time: 06/10/2025 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:37	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:08	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 202 Kids Bathroom
Sink

Lab Sample ID: 250610085-21

Site: Collection
Date/Time: 06/10/2025 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:46	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:13	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 202 Water Fountain

Lab Sample ID: 250610085-22

Site: Collection
Date/Time: 06/10/2025 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:49	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:22	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 203 Teacher Sink

Lab Sample ID: 250610085-23

Site: Collection
Date/Time: 06/10/2025 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:53	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:25	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 203 Kids Bathroom
Sink

Lab Sample ID: 250610085-24

Site: Collection
Date/Time: 06/10/2025 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:56	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:27	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 203 Water Fountain

Lab Sample ID: 250610085-25

Site: Collection
Date/Time: 06/10/2025 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 15:59	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:36	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 204 Teacher Sink

Lab Sample ID: 250610085-26

Site: Collection
Date/Time: 06/10/2025 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:02	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:39	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 204 Kids Bathroom
Sink

Lab Sample ID: 250610085-27

Site: Collection
Date/Time: 06/10/2025 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:05	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:41	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 204 Water Fountain

Lab Sample ID: 250610085-28

Site: Collection Date/Time: 06/10/2025 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0106 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:09	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:44	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 205 Teacher Sink

Lab Sample ID: 250610085-29

Site: Collection Date/Time: 06/10/2025 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:12	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:47	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 205 Kids Bathroom Sink

Lab Sample ID: 250610085-30

Site: Collection Date/Time: 06/10/2025 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:25	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:50	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 205 Water Fountain

Lab Sample ID: 250610085-31

Site: Collection Date/Time: 06/10/2025 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:28	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:53	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 206 Teacher Sink

Lab Sample ID: 250610085-32

Site: Collection Date/Time: 06/10/2025 06:39

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:31	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:55	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 206 Kids Bathroom Sink

Lab Sample ID: 250610085-33

Site: Collection Date/Time: 06/10/2025 06:39

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:34	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 14:58	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 206 Water Fountain

Lab Sample ID: 250610085-34

Site: Collection Date/Time: 06/10/2025 06:39

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0112 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:38	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:01	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 207 Teacher Sink

Lab Sample ID: 250610085-35

Site: Collection Date/Time: 06/10/2025 06:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:41	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:12	



Garden State Laboratories, Inc.

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 207 Kids Bathroom
Sink

Lab Sample ID: 250610085-36

Site: Collection
Date/Time: 06/10/2025 06:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0171 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:44	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:15	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Classroom 207 Water Fountain

Lab Sample ID: 250610085-37

Site: Collection
Date/Time: 06/10/2025 06:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:47	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:18	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Kitchen Sink

Lab Sample ID: 250610085-38

Site: Collection
Date/Time: 06/10/2025 06:43

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:50	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:24	

Sample ID: Saint Justine Nursery, Inc III,
360 New York Ave, Newark NJ -
Teachers Lounge Sink

Lab Sample ID: 250610085-39

Site: Collection
Date/Time: 06/10/2025 06:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	06/17/25 16:53	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/17/25 15:32	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NEOC

Page 1 of 8

GSL CLIENT # SAI04

MICRO #

CHEM. # 250610085-01-05

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Field Blank	6/10/25	6:20			Lead & Copper (First Draw) 85-01	1	P	250ml	A	
X		Classroom 101 Teacher Sink	6/10/25	6:22	✓		Lead & Copper (First Draw) 85-02	1	P	250ml	A	
X		Classroom 101 Kids Bathroom Sink	6/10/25	6:22	✓		Lead & Copper (First Draw) 85-03	1	P	250ml	A	
X		Classroom 101 Water Fountain	6/10/25	6:23	✓		Lead & Copper (First Draw) 85-04	1	P	250ml	A	
X		Classroom 102 Teacher Sink	6/10/25	6:24	✓		Lead & Copper (First Draw) 85-05	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Kevla Rufino Signature: Kevla Rufino Date/Time: 6/10/25 10:25am
 Client/Client's Representative (PRINT): Kevla Rufino Signature: Kevla Rufino Date/Time: 6/10/25 10:38
 1. Received/Relinquished by (PRINT): Faith Jacobus Signature: F Jacobus Date/Time: 6/10/25 10:38
 2. Received/Relinquished by (PRINT): Signature: Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NEOC

Page 2 of 8

GSL CLIENT #

SAI04

MICRO #

CHEM. # 250610085-06-10

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III

Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue

Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*	
X		Classroom 102 Kid's Bathroom	6/10/25	6:25	✓		Lead & Copper (First Draw)	85-06	1	P	250ml	A	
X		Classroom 102 water fountain	6/10/25	6:25	✓		Lead & Copper (First Draw)	85-07	1	P	250ml	A	
X		Classroom 103 Teacher sink	6/10/25	6:28	✓		Lead & Copper (First Draw)	85-08	1	P	250ml	A	
X		Classroom 103 Kid's bathroom sink	6/10/25	6:28	✓		Lead & Copper (First Draw)	85-09	1	P	250ml	A	
X		Classroom 103 water fountain	6/10/25	6:28	✓		Lead & Copper (First Draw)	85-10	1	P	250ml	A	

*Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid

E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Urter/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2

PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$

☐ Composite Fee: \$

☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:

☐ Check #

☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keryla Rufino

Signature: Keryla Rufino

Client/Client's Representative (PRINT): Keryla Rufino

Signature: Keryla Rufino

Date/Time: 6/10/25 6:28

1. Received/Relinquished by (PRINT): Faith Jacobus

Signature: F Jacobus

Date/Time: 6/10/25 10:38

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NEAC

Page 3 of 8

GSL CLIENT #

SAI04

MICRO #

CHEM. # 250610085-11-15

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III

Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue

Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages _____	No.	Type*	Size	Pres.*	Extension
X		Classroom 104 Teacher's sink	6/10/25	6:28	✓		Lead & Copper (First Draw)	85-11	1	P	250ml	A	
X		Classroom 104 Kid's bathroom sink	6/10/25	6:29	✓		Lead & Copper (First Draw)	85-12	1	P	250ml	A	
X		Classroom 104 water fountain	6/10/25	6:29	✓		Lead & Copper (First Draw)	85-13	1	P	250ml	A	
X		Classroom 105 Teacher's sink	6/10/25	6:30	✓		Lead & Copper (First Draw)	85-14	1	P	250ml	A	
X		Classroom 105 Kid's bathroom sink	6/10/25	6:30	✓		Lead & Copper (First Draw)	85-15	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid

E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Clove Oil Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$

☐ Composite Fee: \$

☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:

☐ Check #

☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keyla Rutino

Signature: Keyla Rutino

Client/Client's Representative (PRINT): Keyla Rutino

Signature: Keyla Rutino

Date/Time: 6/10/25 6:30AM

1. Received/Relinquished by (PRINT): Faith Jacobus

Signature: Faith Jacobus

Date/Time: 6/10/25 10:38

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NEOC

Page 4 of 8

GSL CLIENT #

SAI04

MICRO #

CHEM. # 250610085-16-20

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III

Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue

Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Classroom 105 Water Fountain	6/10/25	6:30	✓		Lead & Copper (First Draw) 85-16	1	P	250ml	A	
X		Classroom 201 Teachers Sink	6/10/25	6:32	✓		Lead & Copper (First Draw) 85-17	1	P	250ml	A	
X		Classroom 201 Kids Bathroom sink	6/10/25	6:32	✓		Lead & Copper (First Draw) 85-18	1	P	250ml	A	
X		Classroom 201 Water fountain	6/10/25	6:32	✓		Lead & Copper (First Draw) 85-19	1	P	250ml	A	
X		Classroom 202 Teachers sink	6/10/25	6:33	✓		Lead & Copper (First Draw) 85-20	1	P	250ml	A	

*Container type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (IF RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2

PWSID#:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$

☐ Composite Fee: \$

☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:

☐ Check #

☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT):

Keyla Rufino

Signature: Keyla Rufino

Client/Client's Representative (PRINT):

Keyla Rufino

Signature: Keyla Rufino

Date/Time: 6/10/25 6:33am

1. Received/Relinquished by (PRINT):

Faith Jacobus

Signature: F. Jacobus

Date/Time: 6/10/25 10:38

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NOEC

Page 5 of 8

GSL CLIENT # SAI04

MICRO #

CHEM. # 250610085-21-25

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III Contact/Authorized by: Eleanor Afonso
 Mailing Address: 360 New York Avenue Phone: 973-998-5700
 City/State/Zip: Newark, NJ 07105 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW
 SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab/Comp		SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages _____	No.	Type*	Size	Pres.*	Extension
X		Classroom 202 Kid's bathroom sink	6/10/25	6:33	✓		Lead & Copper (First Draw)	85-21	1	P	250ml	A	
X		Classroom 202 water fountain	6/10/25	6:33	✓		Lead & Copper (First Draw)	85-22	1	P	250ml	A	
X		Classroom 203 Teacher's sink	6/10/25	6:35	✓		Lead & Copper (First Draw)	85-23	1	P	250ml	A	
X		Classroom 203 Kid's bathroom sink	6/10/25	6:35	✓		Lead & Copper (First Draw)	85-24	1	P	250ml	A	
X		Classroom 203 water fountain	6/10/25	6:35	✓		Lead & Copper (First Draw)	85-25	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keyla Rufino	Signature: Keyla Rufino	Date/Time: 6/10/25 6:35 AM
Client/Client's Representative (PRINT): Keyla Rufino	Signature: Keyla Rufino	Date/Time: 6/10/25 10:38
1. Received/Relinquished by (PRINT): Faith Jacobus	Signature: F. Jacobus	Date/Time: 6/10/25 10:38
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22-1°C NEOC

Page 6 of 8

GSL CLIENT #

SAI04

MICRO #

CHEM. # 250610085-26-30

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III

Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue

Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105

Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Classroom 204 Teacher's sink	6/10/25	6:36	✓		Lead & Copper (First Draw) 85-26	1	P	250ml	A	
X		Classroom 204 Kids bathroom sink	6/10/25	6:36	✓		Lead & Copper (First Draw) 85-27	1	P	250ml	A	
X		Classroom 204 Water fountain	6/10/25	6:36	✓		Lead & Copper (First Draw) 85-28	1	P	250ml	A	
X		Classroom 205 Teacher's Sink	6/10/25	6:38	✓		Lead & Copper (First Draw) 85-29	1	P	250ml	A	
X		Classroom 205 Kids bathroom	6/10/25	6:38	✓		Lead & Copper (First Draw) 85-30	1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2

PWSID#:

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$

☐ Composite Fee: \$

☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:

☐ Check #

☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keyla Rufino

Signature: Keyla Rufino

Client/Client's Representative (PRINT): Keyla Rufino

Signature: Keyla Rufino

Date/Time: 6/10/25 6:38 AM

1. Received/Relinquished by (PRINT): Faith Jacobus

Signature: Faith Jacobus

Date/Time: 6/10/25 10:38

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NFOC

Page 7 of 8

GSL CLIENT #

SAI04

MICRO #

CHEM. # 25a010085-31-35

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab/Comp		SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*	
X		Classroom 205 water fountain	6/10/25	6:38	✓				1	P	250ml	A	
X		Classroom 206 Teacher's sink	6/10/25	6:39	✓				1	P	250ml	A	
X		Classroom 206 Kids bathroom sink	6/10/25	6:39	✓				1	P	250ml	A	
X		Classroom 206 water fountain	6/10/25	6:39	✓				1	P	250ml	A	
X		Classroom 207 Teacher's sink	6/10/25	6:40	✓				1	P	250ml	A	

*Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: _____
*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keyla Rufino

Signature: Keyla Rufino

Client/Client's Representative (PRINT): Keyla Rufino

Signature: Keyla Rufino

Date/Time: 6/10/25 6:40AM

1. Received/Relinquished by (PRINT): Faith Jacobus

Signature: Faith Jacobus

Date/Time: 6/10/25 10:38

2. Received/Relinquished by (PRINT):

Signature:

Date/Time:

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

6/10/25 10:38
22.1°C NEOF

Page 8 of 8

GSL CLIENT # SAI04

MICRO #

CHEM. # 250610085-36-39

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☒ DELIVERED BY CLIENT

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Saint Justine Nursery, Inc. III Contact/Authorized by: Eleanor Afonso

Mailing Address: 360 New York Avenue Phone: 973-998-5700

City/State/Zip: Newark, NJ 07105 Fax:

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Saint Justine Nursery, Inc. III, 360 New York Ave, Newark, NJ

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type*	Size	Pres.*	
X		Classroom 207 kids bathroom sink	6/10/25	6:40	✓				1	P	250ml	A	
X		Classroom 207 water fountain	6/10/25	6:40	✓				1	P	250ml	A	
X		Kitchen sink	6/10/25	6:43	✓				1	P	250ml	A	
X		Teachers lounge sink	6/10/25	6:45	✓				1	P	250ml	A	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____

*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cloored Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (If RUSH REQUESTED) Rush Due by:

REPORT FORMAT: ☒ Standard Report ☐ Other/Specify:

☐ Standard Report + E2 PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other:

Note: LEAD & COPPER SAMPLING FOR CHILD CARE FACILITY ON PUBLIC WATER SYSTEM *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED*

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Keyla Rufino	Signature: Keyla Rufino	Date/Time: 6/10/25 6:45 AM
Client/Client's Representative (PRINT): Keyla Rufino	Signature: Keyla Rufino	Date/Time: 6/10/25 10:38
1. Received/Relinquished by (PRINT): Faith Jacobus	Signature: F Jacobus	Date/Time:
2. Received/Relinquished by (PRINT):	Signature:	Date/Time: