



Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Report Date: 03/17/2022

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

For: Saint Justine Nursery, Inc. III
360 New York Ave.

Newark, NJ 07105

Laboratory Director:

Attention: Keyla Rufino

Client Number: SAI04

Sample ID: Classroom 102 Kids
bathroom sink

Lab Sample ID: 220303058-01

Site: Collection Date/Time: 03/03/2022 07:09

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 10:54	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:00	

Sample ID: Classroom 102 Water
fountain

Lab Sample ID: 220303058-02

Site: Collection Date/Time: 03/03/2022 07:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:07	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:02	

Sample ID: Classroom 103 Teacher Sink

Lab Sample ID: 220303058-03

Site: Collection Date/Time: 03/03/2022 07:12

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:12	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:05	



Sample ID: Classroom 103 Kids bathroom sink Lab Sample ID: 220303058-04
 Site: Collection Date/Time: 03/03/2022 07:12
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:16	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:08	

Sample ID: Classroom 103 Water Fountain Lab Sample ID: 220303058-05
 Site: Collection Date/Time: 03/03/2022 07:13
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:21	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:11	

Sample ID: Classroom 104 Teachers Sink Lab Sample ID: 220303058-06
 Site: Collection Date/Time: 03/03/2022 07:16
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:25	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:23	

Sample ID: Classroom 104 Kids Bathroom Sink Lab Sample ID: 220303058-07
 Site: Collection Date/Time: 03/03/2022 07:17
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:30	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:26	

Sample ID: Classroom 104 Water Fountain Lab Sample ID: 220303058-08
 Site: Collection Date/Time: 03/03/2022 07:18
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0116 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:35	



Sample ID: Classroom 104 Water Fountain Lab Sample ID: 220303058-08
 Site: Collection Date/Time: 03/03/2022 07:18
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:29	

Sample ID: Classroom 105 Teachers sink Lab Sample ID: 220303058-09
 Site: Collection Date/Time: 03/03/2022 07:21
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:39	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:31	

Sample ID: Classroom 105 Kids Bathroom sink Lab Sample ID: 220303058-10
 Site: Collection Date/Time: 03/03/2022 07:21
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0140 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:44	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:34	

Sample ID: Classroom 105 Water Fountain Lab Sample ID: 220303058-11
 Site: Collection Date/Time: 03/03/2022 07:23
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 11:57	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:37	

Sample ID: Classroom 201 Teachers Sink Lab Sample ID: 220303058-12
 Site: Collection Date/Time: 03/03/2022 07:26
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:02	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 12:40	



Sample ID: Classroom 201 Kids Bathroom sink Lab Sample ID: 220303058-13
 Site: Collection Date/Time: 03/03/2022 07:26
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0875 mg/l	1.3	0.0100	0.0021	20044	03/16/22 09:24	
Lead, Total Recoverable	EPA 200.8	1	0.00704 mg/l	0.015	0.00100	6E-05	20044	03/10/22 09:56	

Sample ID: Classroom 201 Water Fountain Lab Sample ID: 220303058-14
 Site: Collection Date/Time: 03/03/2022 07:28
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:06	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 19:40	

Sample ID: Classroom 202 Teachers sink Lab Sample ID: 220303058-15
 Site: Collection Date/Time: 03/03/2022 07:30
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:11	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 19:43	

Sample ID: Classroom 202 Water Fountain Lab Sample ID: 220303058-16
 Site: Collection Date/Time: 03/03/2022 07:33
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:15	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 19:52	

Sample ID: Classroom 203 Teachers Sink Lab Sample ID: 220303058-17
 Site: Collection Date/Time: 03/03/2022 07:35
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:20	



Sample ID: Classroom 203 Teachers Sink Lab Sample ID: 220303058-17
 Site: Collection Date/Time: 03/03/2022 07:35
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 19:55	

Sample ID: Classroom 203 Water Fountain Lab Sample ID: 220303058-18
 Site: Collection Date/Time: 03/03/2022 07:35
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:25	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 19:58	

Sample ID: Classroom 204 Teachers sink Lab Sample ID: 220303058-19
 Site: Collection Date/Time: 03/03/2022 07:38
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:29	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:01	

Sample ID: Classroom 204 Water Fountain Lab Sample ID: 220303058-20
 Site: Collection Date/Time: 03/03/2022 07:39
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.144 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:34	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:04	

Sample ID: Classroom 205 Teachers Sink Lab Sample ID: 220303058-21
 Site: Collection Date/Time: 03/03/2022 07:40
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:38	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:13	



Sample ID: Classroom 205 Water Fountain Lab Sample ID: 220303058-22
 Site: Collection Date/Time: 03/03/2022 07:40
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0182 mg/l	1.3	0.0100	0.0021	20044	03/09/22 12:56	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:15	

Sample ID: Classroom 206 Teachers Sink Lab Sample ID: 220303058-23
 Site: Collection Date/Time: 03/03/2022 07:43
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:11	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:18	

Sample ID: Classroom 206 Waters Fountain Lab Sample ID: 220303058-24
 Site: Collection Date/Time: 03/03/2022 07:43
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:16	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:21	

Sample ID: Classroom 207 Teachers Sink Lab Sample ID: 220303058-25
 Site: Collection Date/Time: 03/03/2022 07:46
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:20	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:24	

Sample ID: Classroom 207 Water Fountain Lab Sample ID: 220303058-26
 Site: Collection Date/Time: 03/03/2022 07:46
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0117 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:25	



Sample ID: Classroom 207 Water Fountain Lab Sample ID: 220303058-26
 Site: Collection Date/Time: 03/03/2022 07:46
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:36	

Sample ID: 1st Floor Water Fountain (Hallway) Lab Sample ID: 220303058-27
 Site: Collection Date/Time: 03/03/2022 07:48
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.338 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:29	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:39	

Sample ID: 1st Floor Water Dispenser (Hallway) Lab Sample ID: 220303058-28
 Site: Collection Date/Time: 03/03/2022 07:48
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.342 mg/l	1.3	0.0100	0.0021	20044	03/09/22 13:34	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:42	

Sample ID: 2nd Floor Water Fountain (Hallway) Lab Sample ID: 220303058-29
 Site: Collection Date/Time: 03/03/2022 07:51
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.364 mg/l	1.3	0.0100	0.0021	20044	03/10/22 10:48	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:45	

Sample ID: 2nd Floor Water Dispenser (Hallway) Lab Sample ID: 220303058-30
 Site: Collection Date/Time: 03/03/2022 07:51
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.369 mg/l	1.3	0.0100	0.0021	20044	03/10/22 10:53	



Sample ID: 2nd Floor Water Dispenser (Hallway) Lab Sample ID: 220303058-30
 Site: Collection Date/Time: 03/03/2022 07:51
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 20:48	

Sample ID: Kitchen Sink Lab Sample ID: 220303058-31
 Site: Collection Date/Time: 03/03/2022 07:55
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/10/22 10:57	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 21:03	

Sample ID: 1st Floor Staff Bathroom Lab Sample ID: 220303058-32
 Site: Collection Date/Time: 03/03/2022 07:57
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	0.0116 mg/l	1.3	0.0100	0.0021	20044	03/10/22 11:19	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 21:05	

Sample ID: 2nd Floor Staff Bathroom Lab Sample ID: 220303058-33
 Site: Collection Date/Time: 03/03/2022 07:59
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/10/22 11:24	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 21:14	

Sample ID: Teachers Lounge Sink Lab Sample ID: 220303058-34
 Site: Collection Date/Time: 03/03/2022 08:05
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7	1	< 0.0100 mg/l	1.3	0.0100	0.0021	20044	03/10/22 11:28	
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	03/08/22 21:17	

